Schena, Cristeen

From: Turin, David

Sent: Wednesday, September 02, 2015 2:39 PM **To:** 'Aram Varjabedian'; david.burns@state.ma.us

Cc: Dow, James; Frank Cavaleri

Subject: RE: Hull - violation - NPDES - MA0101231

Hi Aram,

Thank you for the email notification.

Dave

David Turin
U.S. Environmental Protection Agency
Water Technical Unit
Mail code OES04-3
5 Post Office Square - Suite 100
Boston MA 02109 - 3912

Tel. (617) 918-1598 :: Fax (617) 918-0598

turin.david@epa.gov

From: Aram Varjabedian [mailto:avarjabedian@woodardcurran.com]

Sent: Tuesday, September 01, 2015 3:43 PM **To:** david.burns@state.ma.us; Turin, David

Cc: Dow, James; Frank Cavaleri

Subject: Hull - violation - NPDES - MA0101231

Gentlemen:

We received the lab report back from the contract lab for the effluent composite sample collected for the 8/19-20, 2015 period. The result to be reported is 53 mg/L. The final effluent BOD result exceeded the maximum daily limit of 50 mg/L. Also, because the facility samples once per week, there is a weekly excursion also. We believe that this is a one-time incident. On the sample collection day, we were completing the take down of one of the final clarifiers for annual inspection and service, and also cleaning out one of the off line aeration tanks. The added hydraulic and solids loading on the system caused for the reduction in treatment efficiency.

A change in tank cleaning and dewatering strategy was discussed and will be implemented for future work, to minimize the loading impact on the system.

PERMIT LIMITS – BOD MAX DAILY - 50 mg/L.

ACTUAL RESULTS

MAX DAILY – 53 mg/L

BOD AVG WEEKLY - 45 AVG WEEKLY - 53 mg/L

Should you have any questions, please give me a call to discuss.

Sincerely,

Aram

mg/L

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue |Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com

